





### Laboratory Report

Champlain Valley Edu Services	200674
PO Box 455	
1585 Military Turnpike	
Plattsburgh, NY 12901	
Atten: Angela Jennette	

PROJECT: Lead in School Taps, PeruMS/HS  
WORK ORDER: **2105-14562**  
DATE RECEIVED: May 27, 2021  
DATE REPORTED: June 17, 2021  
SAMPLER: LeFevre

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain  
Laboratory Director Plattsburgh, NY

### Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps, PeruMS/HS

WORK ORDER: **2105-14562**  
DATE RECEIVED: 5/27/21

001	Site: HS Kitchen NW Sink			Stagnant:	8.52 Hrs	Date Sampled:	5/27/21	Time:	4:01
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0114	mg/L	EPA 200.8	6/6/21	W SJM	A		
002	Site: HS Kitchen West Kettle			Stagnant:	8.52 Hrs	Date Sampled:	5/27/21	Time:	4:01
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0119	mg/L	EPA 200.8	6/6/21	W SJM	A		
003	Site: HS Kitchen NW Sink - Left Bay			Stagnant:	8.52 Hrs	Date Sampled:	5/27/21	Time:	4:01
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0079	mg/L	EPA 200.8	6/6/21	W SJM	A		
004	Site: HS Kitchen NW Sink - Middle Bay			Stagnant:	8.52 Hrs	Date Sampled:	5/27/21	Time:	4:01
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0023	mg/L	EPA 200.8	6/6/21	W SJM	A		
005	Site: HS Kitchen NW Sink - Right Bay			Stagnant:	8.52 Hrs	Date Sampled:	5/27/21	Time:	4:01
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0080	mg/L	EPA 200.8	6/6/21	W SJM	A		
006	Site: HS Kitchen East Kettle			Stagnant:	8.52 Hrs	Date Sampled:	5/27/21	Time:	4:01
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0057	mg/L	EPA 200.8	6/6/21	W SJM	A		
007	Site: HS Kitchen SE Sink			Stagnant:	8.52 Hrs	Date Sampled:	5/27/21	Time:	4:01
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A		
008	Site: HS Kitchen SW Sink			Stagnant:	8.53 Hrs	Date Sampled:	5/27/21	Time:	4:02
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0061	mg/L	EPA 200.8	6/16/21	W SJM	A		
009	Site: HS Cafeteria			Stagnant:	8.53 Hrs	Date Sampled:	5/27/21	Time:	4:02
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0036	mg/L	EPA 200.8	6/16/21	W SJM	A		
010	Site: D.O. Bathroom			Stagnant:	8.58 Hrs	Date Sampled:	5/27/21	Time:	4:05
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	

### Laboratory Report

CLIENT: Champlain Valley Edu Services	WORK ORDER: <b>2105-14562</b>
PROJECT: Lead in School Taps, PeruMS/HS	DATE RECEIVED: 5/27/21
Lead, Total 0.0019 mg/L EPA 200.8	6/16/21 W SJM A

011	Site: D.O. Kitchen	Stagnant:	8.60 Hrs	Date Sampled:	5/27/21	Time:	4:06
-----	--------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0023	mg/L	EPA 200.8	6/16/21	W SJM	A	

012	Site: HS Teacher Break Room Kitchen	Stagnant:	8.62 Hrs	Date Sampled:	5/27/21	Time:	4:07
-----	-------------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0061	mg/L	EPA 200.8	6/16/21	W SJM	A	

013	Site: Community Room	Stagnant:	8.63 Hrs	Date Sampled:	5/27/21	Time:	4:08
-----	----------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0012	mg/L	EPA 200.8	6/16/21	W SJM	A	

014	Site: Band Room Sink	Stagnant:	8.68 Hrs	Date Sampled:	5/27/21	Time:	4:11
-----	----------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0060	mg/L	EPA 200.8	6/16/21	W SJM	A	

015	Site: MS Gym Bottle Fill Station	Stagnant:	8.73 Hrs	Date Sampled:	5/27/21	Time:	4:14
-----	----------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A	

016	Site: HS Library Office	Stagnant:	8.77 Hrs	Date Sampled:	5/27/21	Time:	4:16
-----	-------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0020	mg/L	EPA 200.8	6/16/21	W SJM	A	

017	Site: HS (Lodge) Bottle Fill Station	Stagnant:	8.78 Hrs	Date Sampled:	5/27/21	Time:	4:17
-----	--------------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A	

018	Site: HS Office Sink	Stagnant:	8.78 Hrs	Date Sampled:	5/27/21	Time:	4:17
-----	----------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0034	mg/L	EPA 200.8	6/16/21	W SJM	A	

019	Site: HS Guidance Bottle Fill Station	Stagnant:	8.80 Hrs	Date Sampled:	5/27/21	Time:	4:18
-----	---------------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A	

## Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps, PeruMS/HS

WORK ORDER: 2105-14562  
DATE RECEIVED: 5/27/21

020	Site: HS Nurse West Sink			Stagnant:	8.83 Hrs	Date Sampled:	5/27/21	Time:	4:20
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0086	mg/L	EPA 200.8	6/16/21	W SJM	A		
021	Site: HS Nurse East Sink			Stagnant:	8.83 Hrs	Date Sampled:	5/27/21	Time:	4:20
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0070	mg/L	EPA 200.8	6/16/21	W SJM	A		
022	Site: HS Break Room/Server			Stagnant:	8.85 Hrs	Date Sampled:	5/27/21	Time:	4:21
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0067	mg/L	EPA 200.8	6/16/21	W SJM	A		
023	Site: MS East Hall Bottle Fill Sta - 1			Stagnant:	8.90 Hrs	Date Sampled:	5/27/21	Time:	4:24
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A		
024	Site: MS Nurse Sink			Stagnant:	8.90 Hrs	Date Sampled:	5/27/21	Time:	4:24
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0022	mg/L	EPA 200.8	6/16/21	W SJM	A		
025	Site: MS Staff Room			Stagnant:	8.95 Hrs	Date Sampled:	5/27/21	Time:	4:27
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A		
026	Site: MS Kitchen Wash Sink (Left)			Stagnant:	8.95 Hrs	Date Sampled:	5/27/21	Time:	4:27
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0189	mg/L	EPA 200.8	6/16/21	W SJM	A		
027	Site: MS Kitchen Wash Sink (Left)			Stagnant:	8.95 Hrs	Date Sampled:	5/27/21	Time:	4:27
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0161	mg/L	EPA 200.8	6/16/21	W SJM	A		
028	Site: MS Kitchen Main Sink			Stagnant:	8.97 Hrs	Date Sampled:	5/27/21	Time:	4:28
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0032	mg/L	EPA 200.8	6/16/21	W SJM	A		
029	Site: Ice Machine			Stagnant:	8.97 Hrs	Date Sampled:	5/27/21	Time:	4:28
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	

**Laboratory Report**

CLIENT:	Champlain Valley Edu Services	WORK ORDER:	<b>2105-14562</b>
PROJECT:	Lead in School Taps, PeruMS/HS	DATE RECEIVED:	5/27/21
Lead, Total	< 0.0010	mg/L	EPA 200.8
			6/16/21
			W SJM
			A

030	Site: MS North Hallway B. F. S. - 1st	Stagnant:	8.97 Hrs	Date Sampled:	5/27/21	Time:	4:28
-----	---------------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A	

031	Site: MS North Hallway B. F. S. - 2nd	Stagnant:	9.03 Hrs	Date Sampled:	5/27/21	Time:	4:32
-----	---------------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A	

032	Site: MS East Hallway B. F. S. - 2nd	Stagnant:	9.07 Hrs	Date Sampled:	5/27/21	Time:	4:34
-----	--------------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/16/21	W SJM	A	

033	Site: MS Staff Break 2nd	Stagnant:	9.07 Hrs	Date Sampled:	5/27/21	Time:	4:34
-----	--------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0038	mg/L	EPA 200.8	6/16/21	W SJM	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY  
Due Date: 11 JUN 21

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: Champlain Valley Education Services		Account #: 200674	SAMPLE SUPPLY INFORMATION	
Email Address: mlefevre@perucsd.org	PWS # Peru Water District			
Contact Person: Matt LeFevre	Project Name: BOCES	Collection Address: 17 School Street		
Phone: 518-643-6050	3T - Lead in Schools	High School - Middle School		
PO #		City: Peru	State: NY	Zip: 12972
		Pag 1 of 3	Collector's Name: LeFevre	

SAMPLE MATRIX CODES				Bottle Type / Volume	Matrix	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead	Analysis Requested:		Lab Use Sample #
DW=drinking water	SW=Surface Water	Compliance? Yes Initial Testing or Repeat Testing								Water Last Used (Date / Time)		
WW=waste water	SD=solid											
MW=monitoring well	SO=soil											
HW=hazardous waste	SL=sludge											
TURNAROUND TIME REQUESTED												
Standard (2-4 weeks)												
Sample ID / Collection Site		Date/Time										
1. HS kitchen NW sink	5/27/2021	4:01am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	001	
2. HS kitchen west kettle	5/27/2021	4:01am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	002	
3. HS kitchen NW sink - left bay	5/27/2020	4:01am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	003	
4. HS kitchen NW sink - middle bay	5/27/2021	4:01am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	004	
5. HS kitchen NW sink - right bay	5/27/2021	4:01am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	005	
6. HS kitchen east kettle	5/27/2020	4:01am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	006	
7. HS kitchen SE sink	5/27/2021	4:01am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	007	
8. HS kitchen SW sink	5/27/2021	4:02am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	008	
9. HS cafeteria	5/27/2020	4:02am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	009	
10. D.O. bathroom	5/27/2021	4:05am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	010	
11. D.O. kitchen	5/27/2021	4:06am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	011	
12. HS teacher break room kitchen	5/27/2020	4:07am	250mL, P	DW	*	Y	N	X		May 26 around 7:30pm	012	

SAMPLE RECEIPT (Lab Use Only)		Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact?	yes	27 May 21	0955	As lead	
Filled to proper volume?	yes			As lead in Drop Box Area	JS
# of Containers	33				

2105-14562



2105-14562

Champlain Valley Edu Services  
Lead in School Taps, Peru HS/H5

\* Samples preserved with NHO3 to pH < 2 after receipt at the lab. @ ~1000 on 7/2x

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY

Analysis Fee \$ \_\_\_\_\_ or A/R \_\_\_\_\_

Terms are net 30 days with a \_\_\_\_\_

Payment Method  Cash  Check  MC/Visa  Money Order  Check, MO, Receipt # \_\_\_\_\_



# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: Champlain Valley Education Services		Account #: 200674	SAMPLE SUPPLY INFORMATION	
Email Address:	mlfevre@perucsd.org		PWS #	Peru Water District
Contact Person:	Matt LeFevre	Project Name	BOCES	
Phone:	518-643-6050		Collection Address:	17 School Street
PO #		3T - Lead in Schools	High School - Middle School	
		City: Peru	State: NY	Zip: 12972
		Pag 2 of 3	Collector's Name: LeFevre	

SAMPLE MATRIX CODES		Compliance? Yes Initial Testing or Repeat Testing	Bottle Type / Volume	Matrix	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead	Analysis Requested:		Lab Use Sample #
DW=drinking water	SW=Surface Water								Water Last Used (Date / Time)		
WW=waste water	SD=solid										
MW=monitoring well	SO=soil										
HW=hazardous waste	SL=sludge										
TURNAROUND TIME REQUESTED											
Standard (2-4 weeks)											
Sample ID / Collection Site		Date/Time									
13. Community Room		5/27/2021 4:08am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 13 001
14. Band Room Sink		5/27/2021 4:11am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 14 002
15. MS Gym bottle fill station		5/27/2020 4:14am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 15 003
16. HS Library Office		5/27/2021 4:16am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 16 004
17. HS (Lodge) bottle fill station		5/27/2021 4:17am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 17 005
18. HS office sink		5/27/2020 4:17am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 18 006
19. HS Guidance bottle fill station		5/27/2021 4:18am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 19 007
20. HS Nurse West sink		5/27/2021 4:20am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 20 008
21. HS Nurse East sink		5/27/2020 4:20am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 21 009
22. HS Break Room/Server		5/27/2021 4:21am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 22 010
23. MS East Hall bottle fill station - 1st		5/27/2021 4:24am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 23 011
24. MS Nurse sink		5/27/2020 4:24am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm 24 012

SAMPLE RECEIPT (Lab Use Only)	Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact?				
Filled to proper volume?				
# of Containers				

\* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY

Analysis Fee \$ \_\_\_\_\_ or A/R

Payment Method  Cash  Check  MC/Visa  Money Order

Terms are net 30 days with an open, up to date account

Check, MO, Receipt # \_\_\_\_\_



# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY  
Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: Champlain Valley Education Services		Account #: 200674	SAMPLE SUPPLY INFORMATION	
Email Address: mlefevre@perucsd.org		PWS # Peru Water District		
Contact Person: Matt LeFevre		Project Name: BOCES	Collection Address: 17 School Street	
Phone: 518-643-6050		3T - Lead in Schools	High School - Middle School	
PO #		City: Peru State: NY Zip: 12972		
Pag 3 of 3		Collector's Name: LeFevre		

SAMPLE MATRIX CODES		Compliance? Yes Initial Testing or Repeat Testing	Bottle Type / Volume	M a t r i x	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead	Analysis Requested:		Lab Use Sample #
DW=drinking water	SW=Surface Water								Water Last Used (Date / Time)		
WW=waste water	SD=solid										
MW=monitoring well	SO=soil										
HW=hazardous waste	SL=sludge										
TURNAROUND TIME REQUESTED											
Standard (2-4 weeks)											
Sample ID / Collection Site	Date/Time										
25. MS staff room	5/27/2021 4:27am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	25 001
26. MS kitchen wash sink (left)	5/27/2021 4:27am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	26 002
27. MS kitchen wash sink (left)	5/27/2020 4:27am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	27 003
28. MS kitchen main sink	5/27/2021 4:28am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	28 004
29. Ice Machine	5/27/2021 4:28am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	29 005
30. MS North Hallway bottle fill station - 1st	5/27/2020 4:28am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	30 006
31. MS North Hallway bottle fill station - 2nd	5/27/2021 4:32am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	31 007
32. MS East Hallway bottle fill station - 2nd	5/27/2021 4:34am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	32 008
33. MS staff break 2nd	5/27/2020 4:34am	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	33 009
	5/27/2021	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	<del>010</del>
	5/27/2021	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	<del>011</del>
	5/27/2020	250mL, P	DW	*	Y	N	X			May 26 around 7:30pm	<del>012</del>

SAMPLE RECEIPT (Lab Use Only)	Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact?				
Filled to proper volume?				
# of Containers				

\* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY

Analysis Fee \$ \_\_\_\_\_ or A/R

Terms are net 30 days with an open, up to date account

Payment Method  Cash  Check  MC/Visa  Money Order

Check, MO, Receipt # \_\_\_\_\_